



note: this detail is required at the second storey joint level. refer to NZBC E2/AS1, clause 9.1.9.4B

Note: this drawing does not apply to dwellings which are created with the equivalent of two storey plus a gable end (i.e. a drained joint is not required between the 2nd storey and the gable if both are clad with THERMASHELL).

23A

Wall: Inter-Storey Flashing

SCALE: 1:2

THERMASHELL